



NOTES

- ① LEADING EDGE OF CROSSWALK BARS SHALL BE EVEN WITH A LINE BETWEEN THE MIDPOINTS OF ASSOCIATED CURB RETURNS, OR AS LOCATED BY FIELD ENGINEER. LOCATION MAY BE ADJUSTED TO ASSURE CURB RAMPS, IF PRESENT, ACCESS THE CROSSWALK
- ② ADDITIONAL 1' WIDE STRIPS REQUIRED AT DESIGNATED SCHOOL CROSSWALKS.
- ③ FOR LANE WIDTHS OF 12' AND LESS CENTER LEADING EDGE OF BARS ON MIDPOINT OF LANE LINE EXTENDED.
- ④ FOR LANE WIDTHS GREATER THAN 12' SPACE BARS EVENLY BETWEEN LANE LINES WITH A MAXIMUM SPACE BETWEEN STRIPES
- ⑤ 2' WIDE x 10' LONG CROSSWALK BARS PARALLEL TO DIRECTION OF VEHICLE TRAVEL.
- ⑥ TRUNCATED DOME PER ADA STANDARDS. TRUNCATED DOMES SHALL BE NON-CONCRETE, POLYMER, COMPOSITE, CAST IN PLACE UNITS COMPLIANT WITH ADA STANDARDS. COLOR SHALL BE UNIFORMLY INTEGRAL THROUGHOUT THE CROSS SECTION AND CONTRASTING COLOR WITH ADJACENT WALKWAY SURFACES PER ADA STANDARDS. SUBMIT SAMPLE TO CITY FOR APPROVAL PRIOR TO INSTALLATION.
- ⑦ BASE OF CURB RAMP TO BE LOCATED WITHIN THE CROSSWALK MARKINGS

DRAWING NUMBER	STD7-22
SCALE	NONE
REVISION DATE	12/13
DEPARTMENT	PW