



VALVE BOX AND EXTENSION

VALVE OPERATING NUT EXTENSION

NOTES:

1. VALVE OPERATING NUT EXTENSIONS ARE REQUIRED WHEN THE VALVE NUT IS MORE THAN THREE (3) FEET BELOW FINISHED GRADE. EXTENSIONS ARE TO BE A MINIMUM OF ONE (1) FOOT LONG. ONLY ONE EXTENSION WILL BE ALLOWED PER VALVE.
2. ALL VALVE OPERATING NUT EXTENSIONS ARE TO BE MADE OF STEEL, SIZED AS NOTED, AND PAINTED WITH TWO (2) COATS OF METAL RUST RESISTANT PAINT.
3. VALVE BOXES SHALL BE CAST IRON, TWO PIECE UNITS, VALVE BOX LID PER LYNNWOOD STANDARD DETAIL 5-4B.
4. VALVE BOXES TO BE ADJUSTED FLUSH WITH FINISHED PAVING. VALVE BOX COLLARS REQUIRED IF VALVE BOX IS OUT OF PAVING AREA. COLLARS TO BE FLUSH WITH FINISHED LANDSCAPE, SOD, OR UNIMPROVED AREAS. SLOPE COLLARS AWAY FROM LID AT 2% (TYP).

DRAWING NUMBER	STD5-4A
SCALE	NONE
REVISION DATE	06/14
DEPARTMENT	PW