



DRIVEWAY DETAIL

N.T.S.

NOTES

1. SIDEWALKS SHALL BE A MINIMUM OF 4" THICK, AND DRIVEWAY APRON SHALL BE A MINIMUM OR 6" THICK, AND SHALL BE 4000PSI CONCRETE, WITH AIR ENTRAINMENT (MIN 4.5 %, MAX 6.5 %).
2. FULL EXPANSION JOINTS SHALL GENERALLY BE PLACED TO MATCH THOSE PLACED IN ADJACENT CURB & GUTTER, WITH MAXIMUM SPACING OF 10 FEET. DUMMY JOINTS EVERY 5 FEET. FINAL SPACING DETERMINATION SHALL BE DECIDED BY THE INSPECTOR IN THE FIELD.
3. SUB GRADE SHALL BE COMPACTED AS SPECIFIED.
4. THE FINISHED SIDEWALK SHALL BE COVERED BY CURING COMPOUND, WATERPROOF PAPER OR PLASTIC SHEETING IN THE EVENT OF RAIN OR OTHER INCLEMENT WEATHER. CURING TIME SHALL BE AS SPECIFIED.
5. ALL JOINTS SHALL BE CLEANED AND EDGED WITH AN EDGER HAVING A 1/4" RADIUS.
6. SIDEWALKS ARE TYPICALLY 5' WIDE, EXCEPT 7' IN COMMERCIAL AREAS, OR AS APPROVED BY THE PUBLIC WORKS DIRECTOR.

CEMENT CONCRETE RESIDENTIAL DRIVEWAY



7-2007
date

3-12
number