



NOTES:

- ① RAMP TEXTURING IS TO BE DONE WITH AN EXPANDED METAL GRATE PLACED AND REMOVED FROM WET CONCRETE TO LEAVE A DIAMOND PATTERN. THE LONG AXIS OF THE DIAMOND SHALL BE PERPENDICULAR TO CURB. GROOVES SHALL BE 1/8" DEEP AND 1/4" WIDE.
- ② FULL DEPTH EXPANSION JOINT.
- ③ NO LIP AT GUTTER LINE.
- ④ CURB RAMPS WILL NOT BE POURED INTEGRAL WITH SIDEWALK AND SHALL BE ISOLATED BY EXPANSION JOINT MATERIAL ON ALL SIDES, BUT NOT AT END OF RAMP ADJACENT TO THE ROADWAY.
- ⑤ 3/4" RADIUS DUMMY JOINT.
- ⑥ TRUNCATED DOME PER ADA STANDARDS. TRUNCATED DOMES SHALL BE NON-CONCRETE, POLYMER, COMPOSITE, CAST IN PLACE UNITS COMPLIANT WITH ADA STANDARDS. COLOR SHALL BE UNIFORMLY INTEGRAL THROUGHOUT THE CROSS SECTION AND CONTRASTING COLOR WITH ADJACENT WALKWAY SURFACES PER ADA STANDARDS. SUBMIT SAMPLE TO CITY FOR APPROVAL PRIOR TO INSTALLATION.

MODIFIED TYPE B CURB RAMP