



NOTES:

1. ORNAMENTAL RAILING SHALL BE CONSTRUCTED OF STEEL CONFORMING TO ASTM A-120.
2. WELDING SHALL CONFORM TO THE REQUIREMENTS OF THE "STRUCTURAL WELDING CODE" AWS D 1.1.
3. PROVIDE SLIP JOINTS AT STAIRWAY EXPANSION JOINTS AND AT EVERY 24 FEET ON CENTER MAXIMUM.
4. MAXIMUM SPACING OF POSTS SHALL BE 8 FEET ON STRAIGHT ALIGNMENT AND 6 FEET ON CURVED ALIGNMENT LESS THAN 30 FEET RADIUS.
5. AFTER FABRICATION, ALL BURRS AND SHARP EDGES SHALL BE REMOVED.
6. APPLY RUST PROOF METAL PRIME AND ONE COAT OF BLACK ORNAMENTAL IRON METAL PAINT.

ORNAMENTAL HANDRAIL



11-2001
date

3-28
number