

Fireworks Stand Checklist

All fireworks stands shall meet the requirements of RCW 70.77, WAC 212-17 and LMC 9.12.

Fireworks Stands Shall:

- Be located:
 - A. Only in commercial zones established by the City.
 - B. At least 100 ft. from other fireworks stands or separated by a street at least 30 ft. wide.
 - C. At least 20 ft. from fireworks storage trailer, truck or container.
 - D. At least 100 ft. from any gasoline station.
 - E. At least 20 ft. from any parked trailer or motor vehicle.
 - F. At least 100 ft. from any discharge of fireworks.
 - G. At least 20 ft. from any smoking.
 - H. At least 20 ft. from any fuel powered generator or stored generator fuel (5 gal. maximum).
 - I. Not more than 150 ft. from an approved access road.
- Have signs posted which state “**NO FIREWORKS DISCHARGE WITHIN 100 FEET**” on all sides of the stand in letters at least four (4) inches high, on contrasting background.
- Have signs posted which state “**NO SMOKING WITHIN 20 FEET**” on all sides of the stand, in letters at least four (4) inches high, on contrasting background.

Setbacks for Fireworks Stands

	Back	Side	Front
Buildings	20	20	40 / 20**
Combustibles	20	20	40 / 20**
Property Lines	5	5	20
Parking	20	20	20
Public Road*	20	20	20
Private Road	5	5	20

NOTE: Clearance distances are not cumulative.

* Measured from the outer edge of the nearest traffic lane.

** If stand is equipped with 135 degree fusible links which will automatically close all sales doors in case of a fire, or is equipped with a wire-mesh screen with openings of not more than one (1) inch which covers not less than 90% of all sales openings.

**THIS SIGN SHALL BE POSTED WITHIN THE FIREWORKS STAND.
IT IS NOT TO BE REMOVED, MUTILATED OR CONCEALED
BY ANY UNAUTHORIZED PERSON**